

655

REC'D
FEB 19 2013
APCO

Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 484220

Compliance Date: ☒ Existing source: May 3, 2013 ☒ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency compression ignition (CI) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name : QuikTrip Corporation

Facility name : QuikTrip Distribution/QuikTrip Kitchen

Facility (physical location) address: 822 QuikTrip Way, Belton, Missouri 64012

My facility is a (please choose one): ☐ Major source ☒ Area source

Owner name/title: QuikTrip Corporation

Owner/company address: 4705 South 129th East Avenue, Tulsa, Oklahoma 74134

Owner telephone number: (918) 615-7700

If the Operator information is different from the Owner, please provide the following:

Operator name/title: Jim Malarkey, Facility Director

Operator telephone number: (816) 425-3748

Operator email address (if available): _____

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine. There are four compression ignition stationary RICE at the facility. A summary of the engines is provided below:


Generator 1. Existing, non-emergency; 1,456 hp

Generator 2: Existing, non-emergency; 1,109 hp

Generator 3. Existing, emergency; 1,120 hp

Generator 4. New, non-emergency; 3,644 hp

I hereby certify that the information presented herein is correct to the best of my knowledge.


(Signature)

2/14/13
(Date)

Jeff McGuffin, Corporate Environmental Project Manager
(Name/title)

(918) 615-7983
(Telephone No.)